

§ 34.17-15

be cut off or made inaccessible in the event of fire in any of the spaces protected. The control space shall be as convenient as practicable to one of the main escapes from the spaces protected, and shall be marked as required by § 35.40-10 of this subchapter. Where pumps are required, it shall not be necessary that they be started from the control space.

(c) Complete, but simple instructions for the operation of the system shall be located in a conspicuous place at or near the controls.

(d) The valves to the various spaces served shall be marked as required by § 35.40-10 of this subchapter.

§ 34.17-15 Piping—T/ALL.

(a) All piping, valves, and fittings shall meet the applicable requirements of subchapter F (Marine Engineering) of this chapter.

(b) All piping, valves, and fittings of ferrous materials shall be protected inside and outside against corrosion unless specifically approved otherwise by the Commandant.

(c) All piping, valves, and fittings shall be securely supported, and where necessary, protected against injury.

(d) Drains and dirt traps shall be fitted where necessary to prevent the accumulation of dirt or moisture.

(e) Piping shall not be used for any other purpose than firefighting, drills and testing.

§ 34.17-20 Discharge outlets—T/ALL.

(a) Discharge outlets shall be of an approved type.

§ 34.17-25 Additional protection required—T/ALL.

(a) In order that any residual fires above the floor plates may be extinguished when a foam system is installed for the protection of machinery spaces, at least 2 fire hydrants, in addition to those required for the machinery space by subpart 34.10, shall be installed outside of the machinery space entrance. Such hydrants shall be fitted with sufficient hose so that any part of the machinery space may be reached with at least 2 streams of water, and each hose shall be equipped with an approved combination nozzle and applicator.

46 CFR Ch. I (10-1-08 Edition)

§ 34.17-90 Installations contracted for prior to January 1, 1962—T/ALL.

(a) Installations contracted for prior to January 1, 1962, shall meet the following requirements:

(1) Existing arrangements, materials, and facilities previously approved shall be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standards as the original installation.

(2) The details of the systems shall be in general agreement with §§ 34.17-5 through 34.17-20, insofar as is reasonable and practicable. Installations contracted for prior to November 19, 1952, need not comply with paragraph (a)(2) of § 34.17-5 and § 34.17-25. A 6-inch blanket of foam in 3 minutes for machinery spaces and pumprooms will be considered as meeting the requirements of § 34.17-5.

(3) Where a system is installed to protect a tank, it shall be so designed and arranged as to spread a blanket of foam over the entire liquid surface of the tank within the range of usual trim. The arrangement of piping shall be such as to give a relatively uniform distribution over the entire area protected.

(4) For tanks, the rate of discharge to foam outlets protecting the hazard shall be as set forth in § 34.17-5(b), except that the value of 1 gallon per minute shall be substituted in both cases for the value of 1.6 gallons per minute. The quantity of foam provided shall be sufficient to operate the equipment for 5 minutes.

(5) On installations installed prior to November 19, 1952, a semiportable foam generator using a dry-chemical mixture or mechanical foam in conjunction with the fire lines may be substituted for the fixed system subject to the following conditions:

(i) There shall be at least one fire pump of suitable capacity available which can be operated and controlled from outside the space protected.

(ii) Stop valves shall be installed in the line so that if any portion of the fire main is ruptured, the foam generator may still be operated. Connections